

Daily Gas & Condensate Production and Distribution Report

I. Production

| Company | Gas Fields | No. of Producing Wells | Capacity | Production | | Pro. as a % of T.Cap.(Gas) | Pro. as a % of T. Prod.(Gas) |
|-----------------------|----------------------------|------------------------|----------|------------|------------|----------------------------|------------------------------|
| | | | | Gas | Condensate | | |
| 1. BGFLC | Tilas | 26 | 542 | 396.4 | 373.0 | 10.5 | 13.4 |
| | Habiganj | 8 | 225 | 133.9 | 6.6 | 3.6 | 1.1 |
| | Bakhrabad | 7 | 43 | 32.6 | 39.0 | 0.9 | 0.9 |
| | Narsingdi | 2 | 30 | 25.8 | 31.0 | 0.7 | 0.9 |
| | Meghna | 1 | 11 | 3.4 | 5.5 | 0.1 | 0.1 |
| Sub-Total | | 44 | 851 | 592.2 | 455.1 | 15.7 | 20.0 |
| 2. SGFL | Sylhet | 1 | 6 | 5.4 | 29.6 | 0.1 | 0.2 |
| | Kailashtila #1 (Silicagel) | 1 | 13 | 0.1 | 1.1 | 0.0 | 0.0 |
| | Kailashtila #2 (MSTE) | 3 | 55 | 25.8 | 334.9 | 0.7 | 0.9 |
| | Rashidpur | 5 | 60 | 45.2 | 39.5 | 1.2 | 1.5 |
| | Beanibazar | 1 | 15 | 14.2 | 216.2 | 0.4 | 0.5 |
| Sub-Total | | 11 | 149 | 90.8 | 621.4 | 2.4 | 3.1 |
| 3. BAPEX | Salda | 2 | 3 | 3.4 | 1.8 | 0.1 | 0.1 |
| | Fenchuganj | 2 | 26 | 12.0 | 3.4 | 0.3 | 0.4 |
| | Shahbazpur | 4 | 50 | 83.3 | 9.2 | 2.2 | 2.8 |
| | Semutung | 2 | 3 | 0.7 | 0.0 | 0.0 | 0.0 |
| | Sundalpur | 1 | 5 | 8.0 | 0.4 | 0.2 | 0.3 |
| | Srikail | 3 | 40 | 31.3 | 130.4 | 0.8 | 1.1 |
| | Begumganj | 1 | 10 | 8.1 | 2.9 | 0.2 | 0.3 |
| Rupganj | 0 | 8 | 0.0 | 0.0 | 0.0 | 0.0 | |
| Sub-Total | | 15 | 145 | 146.8 | 148.0 | 3.9 | 5.0 |
| Sub-Total (1+2+3) | | 70 | 1145 | 829.7 | 1224.6 | 22.1 | 28.0 |
| 4. IOCs | Jalalabad | 7 | 270 | 177.2 | 861.8 | 4.7 | 6.0 |
| | CHEVRON | 5 | 42 | 18.6 | 1.7 | 0.5 | 0.6 |
| | Bibiyana | 26 | 1200 | 1103.4 | 6217.1 | 29.3 | 37.3 |
| | TULLOW | 5 | 103 | 45.2 | 134.0 | 1.2 | 1.5 |
| Sub-Total | | 43 | 1615 | 1344.4 | 7214.5 | 35.8 | 45.4 |
| 5. RPGCL (R-LNG) | | | 1000 | 786.9 | | 20.9 | 26.6 |
| | Sub-Total | | 0 | 1000 | 786.9 | 0.0 | 20.9 |
| Sub-Total (1+2+3+4+5) | | 113 | 3760 | 2960.9 | 8439.1 | 78.7 | 100.0 |

III. RPGCL Production

| Feed Received | | Production | | |
|---------------|-------|------------|-----|-----|
| NGL | Cond. | LPG | MS | HSD |
| 0.0 | 0.0 | 0 | 0.0 | 0.0 |

N-S & RA pipeline
Delivered from N-S pipeline

| | |
|--------------|---------------|
| AB1 | 0.0 |
| AB2 | 0.0 |
| BB | 217.5 |
| VS3 | 124.0 |
| AM | 323.6 |
| BD | 499.9 |
| Total | 1165.0 |

Remarks:

* RPGCL Shutdown.

II. Distribution

| Company | Power | | Fertilizer | | Others-Supl. | Total | Remarks |
|-------------------------------------|-----------------------------|--------|------------|------------|--------------|--------|---------|
| | Demand | Supply | Company | Max.Demand | | | |
| TGTDCL | Ghorashal (1315 MW) | 148.0 | 88.0 | JFCL | 45.0 | 40.8 | 1199.7 |
| | Max (G)-78 MW Rent | 20.0 | 0.0 | UFFL | 45.0 | 6.5 | |
| | Aggreko (GSL)-145 MW Rent | 38.0 | 0.0 | PUFFL | 14.0 | 0.0 | |
| | Siddhirganj (210 MW) | 38.0 | 0.0 | | | | |
| | Siddhirganj (2x120 MW) | 52.0 | 51.1 | | | | |
| | HPS (100 MW) | 16.0 | 0.0 | | | | |
| | HPS(EGCB) 412 MW | 68.0 | 58.8 | | | | |
| | Meghnaghat IPP 450 MW | 75.0 | 72.0 | | | | |
| | Summit Meghn. 335 MW | 55.0 | 53.5 | | | | |
| | Tongi (80 MW) | 26.0 | 0.0 | | | | |
| | RPCL (210 MW) | 40.0 | 12.1 | | | | |
| | Madhabdi (27+10 MW) REB | 9.0 | 5.1 | | | | |
| | Ashulia (24+10 MW) REB | 10.0 | 5.6 | | | | |
| | Doreen Tangail 22 MW SIPP | 5.0 | 4.2 | | | | |
| | Doreen Narsingdi 22 MW SIPP | 5.0 | 4.0 | | | | |
| | Maona 33 MW SIPP | 8.0 | 1.8 | | | | |
| | Rupganj 33 MW SIPP | 8.0 | 5.5 | | | | |
| EGCB Siddhirganj 335 MW | 55.0 | 49.4 | | | | | |
| HPL (360 MW) | 55.0 | 51.6 | | | | | |
| Regent 108 MW | 27.0 | 0.0 | | | | | |
| Sub-Total | | 750.0 | 462.7 | | 104.0 | 47.4 | 1199.7 |
| BGDCL | Ashuganj 500 MW* | | | AFCL | 52.0 | 0.0 | 89.1 |
| | Ashuganj 55 MW rental | 71.0 | 0.0 | | | | 9.2 |
| | Ashuganj 53 MW rental | | | | | | |
| | Ashuganj -80 MW Rent | 0.0 | 0.0 | | | | |
| | Ashuganj 225MW | 40.0 | 32.0 | | | | |
| | Ashuganj 200 MW Modular | 40.0 | 0.0 | | | | |
| | APS 450 MW CCPP S | 65.0 | 41.2 | | | | |
| | APS 450 MW CCPP N | 65.0 | 46.6 | | | | |
| | APS 450 MW CCPP E | 75.0 | 39.6 | | | | |
| | Feni-22 MW SIPP | 5.2 | 4.1 | | | | |
| | Mohipal-11 MW SIPP | 2.7 | 1.8 | | | | |
| | Jangalia-33 MW SIPP | 7.8 | 6.2 | | | | |
| | Chandpur 150 MW CCPP | 34.0 | 0.0 | | | | |
| | Comilla REB 24 MW | 6.2 | 4.5 | | | | |
| Midland Power 51 MW | 12.0 | 8.1 | | | | | |
| Sub-Total | | 423.9 | 184.1 | | 52.0 | 0.0 | 98.3 |
| KGDCL | Raozan (2x210) MW | 95.0 | 0.0 | CUFL | 52.0 | 3.4 | 174.7 |
| | Sikalbaha (40 MW) | 12.0 | 0.0 | KAFCO | 63.0 | 39.6 | 0.0 |
| | Sikalbaha (225+150+65) MW | 73.0 | 36.4 | | | | |
| | Barabkunda 22 MW SIPP | 5.0 | 2.6 | | | | |
| Sub-Total | | 185.0 | 39.0 | | 115.0 | 43.0 | 174.7 |
| JGTDSL | Shahjibazar 2x30 MW | 18.0 | 18.2 | SFCL | 45.0 | 28.0 | 102.7 |
| | S.Bazar 3 yrs rental 50 MW | 12.0 | 0.0 | | | | |
| | S.Bazar 15 yrs rent 86 MW | 20.0 | 16.8 | | | | |
| | S.Bazar 330 MW | 47.0 | 0.0 | | | | |
| | S.Bazar 100 MW | 18.0 | 0.0 | | | | |
| | Fenchuganj CC1 90 MW | 17.0 | 9.1 | | | | |
| | Fenchuganj CC2 105 MW | 18.0 | 9.0 | | | | |
| | Kumargaon 20 MW | 2.0 | 5.6 | | | | |
| | K.gaon 3 yrs rent 50 MW | 12.0 | 0.0 | | | | |
| | K.gaon 15 yrs rent 10 MW | 3.0 | 2.4 | | | | |
| | K gaon 142 MW CCPP | 36.0 | 35.7 | | | | |
| | Habiganj 11 MW SIPP | 3.0 | 2.0 | | | | |
| | F.ganj 15 yrs rent 51 MW | 13.0 | 10.1 | | | | |
| | F.ganj 3 yrs rent 50 MW | 10.0 | 11.1 | | | | |
| | Shahjahanullah pgl Rent | 5.0 | 5.1 | | | | |
| | Bibiyana-2 341 MW | 50 | 48.2 | | | | |
| | Bibiyana-3 400 MW | 40 | 57.9 | | | | |
| Bibiyana-S,400 MW,PDB | 43 | 53.2 | | | | | |
| Khushiyara 163 MW | 28 | 28.8 | | | | | |
| Sub-Total | | 395.0 | 313.3 | | 45.0 | 28.0 | 102.7 |
| PGCL | Baghabari (100+71 MW) | 50.0 | 0.0 | | | | 26.6 |
| | Bogra 15 yrs rent (20 MW) | 5.0 | 0.0 | | | | |
| | Ullapara 11 MW SIPP | 3.0 | 0.8 | | | | |
| | Bogra 3 yrs rent (20 MW) | 5.0 | 0.0 | | | | |
| | NWPGCL Unit -1 | 38.0 | 0.0 | | | | |
| | NWPGCL Unit -2 | 38.0 | 12.0 | | | | |
| | NWPGCL Unit -3 | 38.0 | 14.5 | | | | |
| NWPGCL Unit -4 | 70.0 | 53.0 | | | | | |
| Sub-Total | | 247.0 | 80.3 | | 0.0 | | 26.6 |
| SGCL | Bhola 3 yrs rent 34.5 MW | 10.0 | 8.1 | | | | 4.2 |
| | Bhola 225 MW | 35.0 | 33.5 | | | | |
| | Bheramara 360MW | 65.0 | 26.0 | | | | |
| | Aggreko 95MW | 26.0 | 0.0 | | | | |
| | NBBL 220MW | 38.0 | 36.7 | | | | |
| Sub-Total | | 174.0 | 104.3 | | 0.0 | | 4.2 |
| Total : | | 2174.9 | 1183.7 | | 316.0 | 118.3 | 1606.2 |
| (Considering diversity factor 0.85) | | 1849 | | | 269 | | 2908.2 |
| Non-grid power | | | | | | | |
| TGTDCL | | 81.2 | | | | | |
| KGDCL | | 12.0 | | | | | |
| Total Non-Grid Power | | 93.2 | | | | 93.2 | |
| Grand Total | | 2174.9 | 1276.9 | 316.0 | 118.3 | 1606.2 | 3001.5 |
| % of Total Distribution | | 4.3% | | 4% | | 54% | |