

Units:

Gas in MMCFD
 Condensate/ NGL/ MS/ HSD in BBLD
 LPG in Kg

Daily Gas & Condensate Production and Distribution Report

I. Production

| Company | Gas Fields | No. of Producing Wells | Capacity | Production | | Pro. as a % of T.Cap(Gas) | Pro. as a % of T. Prod(Gas) |
|------------------|--------------------------------|------------------------|-------------|---------------|---------------|---------------------------|-----------------------------|
| | | | | Gas | Condensate | | |
| 1. BGFCL | Titas | 26 | 542 | 378.1 | 315.0 | 9.9 | 12.2 |
| | Habiganj | 8 | 225 | 116.2 | 6.6 | 3.0 | 1.0 |
| | Bakhrabad | 7 | 43 | 30.4 | 33.0 | 0.8 | 0.8 |
| | Narsingdi | 2 | 30 | 24.3 | 30.0 | 0.6 | 0.8 |
| | Meghna | 1 | 11 | 3.8 | 5.5 | 0.1 | 0.1 |
| | Sub-Total | 44 | 851 | 552.9 | 390.1 | 14.4 | 17.8 |
| 2. SGFL | Sylhet | 3 | 6 | 5.6 | 35.4 | 0.1 | 0.2 |
| | Kailashtila #1 (Silicagel) | 0 | 0 | 0.0 | 0.0 | 0.0 | 0.0 |
| | Kailashtila #2 (MSTE) | 2 | 30 | 28.8 | 390.7 | 0.8 | 0.9 |
| | Rashidpur | 7 | 67 | 68.1 | 39.6 | 1.8 | 2.2 |
| | Beanibazar | 2 | 15 | 15.2 | 232.9 | 0.4 | 0.5 |
| | Sub-Total | 14 | 118 | 117.7 | 698.6 | 3.1 | 3.8 |
| 3. BAPEX | Salda | 2 | 3 | 3.4 | 1.7 | 0.1 | 0.1 |
| | Fenchuganj | 2 | 26 | 9.3 | 3.3 | 0.2 | 0.3 |
| | Shahbazpur | 4 | 50 | 72.9 | 10.6 | 1.9 | 2.3 |
| | Semutung | 2 | 3 | 1.0 | 0.0 | 0.0 | 0.0 |
| | Sundalpur | 1 | 5 | 3.4 | 0.0 | 0.0 | 0.1 |
| | Srikail | 3 | 40 | 23.7 | 89.7 | 0.6 | 0.8 |
| | Begumganj | 1 | 10 | 7.8 | 2.5 | 0.2 | 0.3 |
| Rupganj | 0 | 8 | 0.0 | 0.0 | 0.0 | 0.0 | |
| | Sub-Total | 15 | 145 | 121.5 | 107.6 | 3.2 | 3.9 |
| | Sub-Total (1+2+3) | 73 | 1114 | 792.1 | 1196.3 | 20.7 | 25.5 |
| 4. IOCs | Jalalabad | 7 | 270 | 155.4 | 1028.8 | 4.1 | 5.0 |
| | CHEVRON | 5 | 42 | 18.1 | 1.7 | 0.5 | 0.6 |
| | Bibiyan | 26 | 1200 | 1019.1 | 5680.7 | 26.6 | 32.8 |
| | TULLOW | 5 | 103 | 40.6 | 121.0 | 1.1 | 1.3 |
| | Sub-Total | 43 | 1615 | 1233.1 | 6832.1 | 32.2 | 39.7 |
| 5. RPGCL (R-LNG) | | | 1100 | 1080.2 | | 28.2 | 34.8 |
| | | | 0 | 1100 | 1080.2 | 0.0 | 28.2 |
| | Sub-Total | | | | | | |
| | Grand Total (1+2+3+4+5) | 116 | 3829 | 3105.3 | 8028.5 | 81.1 | 100.0 |

III. RPGCL Production

| Feed Received | | Production | | |
|---------------|-------|------------|-----|-----|
| NGL | Cond. | LPG | MS | HSD |
| 0.0 | 0.0 | 0 | 0.0 | 0.0 |

N-S & RA pipeline
 Delivered from N-S pipeline

| | |
|--------------|---------------|
| AB1 | 0.0 |
| AB2 | 0.0 |
| BB | 227.0 |
| VS3 | 168.0 |
| AM | 446.8 |
| BD | 469.8 |
| Total | 1311.7 |

Remarks:

* RPGCL Shutdown.

II. Distribution

| Company | Power | | Fertilizer | | Others-Supl. | Total | Remarks |
|--------------------------|-----------------------------|------------------|---------------|--------------|--------------|--------------|---|
| | Power Plants | Demand | Supply | Max.Demand | | | |
| TGTDCI | Ghorashal (1315 MW) | 148.0 | 45.9 | JFCL | 45.0 | 0.8 | 1225.5 |
| | SUMMIT MEGHT-2 (583) | 96.0 | 60.3 | GPFPLC | 72.0 | 71.7 | |
| | Aggreko (GSL)-145 MW Rent | 38.0 | 0.0 | | | | * Doreen Narsingdi 22 MW SIPP Shutdown. |
| | UNIQUE MEGHT. (584 MW) | 96.0 | 64.7 | | | | * Doreen Tangail 22 MW SIPP Shutdown. |
| | Siddhirganj (2x120 MW) | 52.0 | 49.0 | | | | * HPS (100 MW) Shutdown. |
| | HPS (100 MW) | 16.0 | 0.0 | | | | * Tongi (80 MW) Shutdown |
| | HPS(EGCB) 412 MW | 68.0 | 66.0 | | | | * Aggreko (GSL)-145 MW Rent Shutdown |
| | Meghnaghat IPP 450 MW | 75.0 | 71.9 | | | | * HPL (360 MW) Shutdown. |
| | Summit Meghn. 335 MW | 55.0 | 52.2 | | | | * JFCL Shutdown. |
| | Tongi (80 MW) | 26.0 | 0.0 | | | | |
| | RPCL (210 MW) | 40.0 | 17.4 | | | | |
| | Madhabdi (27+10 MW) REB | 9.0 | 3.6 | | | | |
| | Ashulia (24+10 MW) REB | 10.0 | 4.1 | | | | |
| | Doreen Tangail 22 MW SIPP | 5.0 | 0.0 | | | | |
| | Doreen Narsingdi 22 MW SIPP | 5.0 | 0.0 | | | | |
| | Maona 33 MW SIPP | 8.0 | 7.0 | | | | |
| | Rupganj 33 MW SIPP | 8.0 | 6.9 | | | | |
| EGCB Shiddhirganj 335 MW | 55.0 | 52.1 | | | | | |
| HPL (360 MW) | 55.0 | 0.0 | | | | | |
| Regent 108 MW | 27.0 | 16.6 | | | | | |
| | Sub-Total | 892.0 | 517.8 | | 117.0 | 72.5 | 1815.8 |
| BGDCL | Ashuganj 500 MW* | | | AFCL | 52.0 | 0.0 | 81.6 |
| | Ashuganj 55 MW rental | 71.0 | 17.8 | | | | 11.6 |
| | Ashuganj 53 MW rental | | | | | | |
| | Ashuganj -80 MW Rent | 0.0 | 0.0 | | | | |
| | Ashuganj 225MW | 40.0 | 37.2 | | | | |
| | Ashuganj 200 MW Modular | 40.0 | 3.3 | | | | |
| | APS 450 MW CCPP S | 65.0 | 49.6 | | | | |
| | APS 450 MW CCPP N | 65.0 | 38.3 | | | | |
| | APS 450 MW CCPP E | 75.0 | 50.8 | | | | |
| | Feni-22 MW SIPP | 5.2 | 0.0 | | | | |
| | Mohipal-11 MW SIPP | 2.7 | 0.0 | | | | |
| | Jangalia-33 MW SIPP | 7.8 | 2.6 | | | | |
| | Chandpur 150 MW CCPP | 34.0 | 0.0 | | | | |
| Comilla REB 24 MW | 6.2 | 3.6 | | | | | |
| Midland Power 51 MW | 12.0 | 9.4 | | | | | |
| | Sub-Total | 423.9 | 212.6 | | 52.0 | 0.0 | 93.2 |
| KGDCL | Raozan (2x210) MW | 95.0 | 34.3 | CUFL | 52.0 | 5.0 | 171.3 |
| | Sikalbaha (40 MW) | 12.0 | 0.0 | KAFCCO | 63.0 | 43.1 | 1.4 |
| | Sikalbaha (225+150+65) MW | 73.0 | 36.2 | | | | |
| | Barabkunda 22 MW SIPP | 5.0 | 1.1 | | | | |
| | Sub-Total | 185.0 | 71.7 | | 115.0 | 48.1 | 172.8 |
| JGTDSL | Shahjibazar 2x30 MW | 18.0 | 17.9 | SFCL | 45.0 | 3.2 | 97.8 |
| | S.Bazar 3 yrs rental 50 MW | 12.0 | 0.0 | | | | |
| | S.Bazar 15 yrs rent 86 MW | 20.0 | 0.0 | | | | |
| | S.Bazar 330 MW | 47.0 | 0.0 | | | | |
| | S.Bazar 100 MW | 18.0 | 14.8 | | | | |
| | Fenchuganj CC1 90 MW | 17.0 | 9.1 | | | | |
| | Fenchuganj CC2 105 MW | 18.0 | 9.0 | | | | |
| | Kumargaon 20 MW | 2.0 | 0.0 | | | | |
| | K.gaoon 3 yrs rent 50 MW | 12.0 | 0.0 | | | | |
| | K.gaoon 15 yrs rent 10 MW | 3.0 | 0.0 | | | | |
| | K.gaoon 142 MW CCPP | 36.0 | 35.7 | | | | |
| | Habiganj 11 MW SIPP | 3.0 | 2.1 | | | | |
| | F.ganj 15 yrs rent 51 MW | 13.0 | 11.7 | | | | |
| | F.ganj 3 yrs rent 50 MW | 10.0 | 8.1 | | | | |
| | Shahjahanullah pgcl Rent | 5.0 | 2.8 | | | | |
| | Bibiyan-2 341 MW | 50 | 9.4 | | | | |
| | Bibiyan-3 400 MW | 40 | 59.6 | | | | |
| | Bibiyan-S,400 MW,PDB | 43 | 56.1 | | | | |
| | Khushivara 163 MW | 28 | 26.3 | | | | |
| | | Sub-Total | 395.0 | 262.7 | | 45.0 | 3.2 |
| PGCL | Baghabari (100+71 MW) | 50.0 | 0.0 | | | | 22.5 |
| | Bogra 15 yrs rent (20 MW) | 5.0 | 0.0 | | | | |
| | Ullapara 11 MW SIPP | 3.0 | 2.2 | | | | |
| | Bogra 3 yrs rent (20 MW) | 5.0 | 0.0 | | | | |
| | NWPGCL Unit -1 | 38.0 | 33.0 | | | | |
| | NWPGCL Unit -2 | 38.0 | 34.7 | | | | |
| | NWPGCL Unit -3 | 38.0 | 0.0 | | | | |
| NWPGCL Unit -4 | 70.0 | 58.9 | | | | | |
| | Sub-Total | 247.0 | 128.8 | | 0.0 | 0.0 | 22.5 |
| SGCL | Bhola 3 yrs rent 34.5 MW | 10.0 | 1.9 | | | | 4.6 |
| | Bhola 225 MW | 35.0 | 33.2 | | | | |
| | Bheramara 360MW | 65.0 | 61.3 | | | | |
| | Aggreko 95MW | 26.0 | 0.0 | | | | |
| | NBBL 220MW | 38.0 | 35.4 | | | | |
| | Sub-Total | 174.0 | 131.8 | | 0.0 | 0.0 | 4.6 |
| | Total : | 2316.9 | 1325.3 | | 329.0 | 123.8 | 1616.4 |
| | | | | | | | 3065.5 |
| | | | | | | | 3163.8 |

(Considering diversity factor 0.85)

Non-grid power

| | | | | | | |
|-----------------------------|---------------|---------------|--------------|--------------|---------------|---------------|
| TGTDCI | 85.9 | | | | | |
| KGDCL | 12.5 | | | | | |
| Total Non-Grid Power | 98.4 | | | | | |
| Grand Total | 2316.9 | 1423.6 | 329.0 | 123.8 | 1616.4 | 3163.8 |
| % of Total Distribution | 45% | | | 4% | 51% | 100% |