

Units:

Gas in MMCFD  
 Condensate/ NGL/ MS/ HSD in BBLD  
 LPG in Kg

**Daily Gas & Condensate Production and Distribution Report**

**I. Production**

Company	Gas Fields	No. of Producing Wells	Capacity	Production		Pro. as a % of	
				Gas	Condensate	T.Cap.(Gas)	T. Prod.(Gas)
1. BGFL	Titas	26	542	376.4	327.0	9.8	14.0
	Habiganj	8	225	112.1	6.5	2.9	1.1
	Bakhrabad	7	43	29.3	32.0	0.8	0.9
	Narsingdi	2	30	23.0	29.0	0.6	0.9
	Meghna	1	11	4.1	4.9	0.1	0.2
	<b>Sub-Total</b>	<b>44</b>	<b>851</b>	<b>544.9</b>	<b>399.4</b>	<b>14.2</b>	<b>20.3</b>
2. SGFL	Sylhet	3	6	4.7	26.9	0.1	0.2
	Kailashtila #1 (Silicagel)	0	0	0.0	0.0	0.0	0.0
	Kailashtila #2 (MSTE)	2	30	40.3	302.7	1.1	1.5
	Rashidpur	7	67	69.9	41.8	1.8	2.6
	Beanibazar	2	15	14.9	222.3	0.4	0.6
	<b>Sub-Total</b>	<b>14</b>	<b>118</b>	<b>129.7</b>	<b>593.7</b>	<b>3.4</b>	<b>4.8</b>
3. BAPEX	Salda	2	3	2.6	0.8	0.1	0.1
	Fenchuganj	2	26	8.7	1.5	0.2	0.3
	Shahbazpur	4	50	59.5	10.1	1.6	2.2
	Semutung	2	3	1.0	0.0	0.0	0.0
	Sundalpur	1	5	3.0	0.0	0.1	0.1
	Srikail	3	40	25.4	98.2	0.7	0.9
	Begumganj	1	10	7.4	2.8	0.2	0.3
	Rupganj	0	8	0.0	0.0	0.0	0.0
	<b>Sub-Total</b>	<b>15</b>	<b>145</b>	<b>107.5</b>	<b>113.3</b>	<b>2.8</b>	<b>4.0</b>
	<b>Sub-Total (1+2+3)</b>	<b>73</b>	<b>1114</b>	<b>782.1</b>	<b>1106.4</b>	<b>20.4</b>	<b>29.2</b>
4. IOCs	Jalalabad	7	270	150.9	817.3	3.9	5.6
	CHEVRON	5	42	15.2	1.2	0.4	0.6
	TULLOW	5	103	37.4	107.0	1.0	1.4
	<b>Sub-Total</b>	<b>43</b>	<b>1615</b>	<b>1196.2</b>	<b>6545.5</b>	<b>31.2</b>	<b>44.6</b>
5. RPGCL (R-LNG)			1100	701.8		18.3	26.2
			0	1100	701.8	0.0	18.3
	<b>Sub-Total</b>		<b>1100</b>	<b>701.8</b>	<b>0.0</b>	<b>18.3</b>	<b>26.2</b>
	<b>Grand Total (1+2+3+4+5)</b>	<b>116</b>	<b>3829</b>	<b>2680.1</b>	<b>7651.9</b>	<b>70.0</b>	<b>100.0</b>

**III. RPGCL Production**

Feed Received		Production		
NGL	Cond.	LPG	MS	HSD
0.0	0.0	0	0.0	0.0

N-S & RA pipeline  
 Delivered from N-S pipeline

AB1	0.0
AB2	0.0
BB	158.2
VS3	128.1
AM	433.3
BD	406.9
<b>Total</b>	<b>1126.5</b>

Remarks:

**II. Distribution**

Company	Power		Fertilizer		Others-Supl.	Total	Remarks
	Power Plants	Demand	Supply	Max.Demand			
TGTDCI	Ghorashal (1315 MW)	148.0	0.0	JFCL	45.0	2.0	* RELIANCE POWER (718MW) Shutdown. * Summit Meghn. 335 MW Shutdown. * Ghorashal (1315 MW) Shutdown. * Aggreko (GSL)-145 MW Rent Shutdown * UNIQUE MEGHT. (584 MW) Shutdown * Siddhirganj (2x120 MW) Shutdown. * HPS (100 MW) Shutdown. * Doreen Tangail 22 MW SIPP Shutdown. * Doreen Narsingdi 22 MW SIPP Shutdown. * HPL ( 360 MW ) Shutdown. * Regent 108 MW * JFCL Shutdown.
	SUMMIT MEGHT-2 (583)	96.0	37.0	GPFPLC	72.0	71.7	
	Aggreko (GSL)-145 MW Rent	38.0	0.0				
	UNIQUE MEGHT. (584 MW)	96.0	0.0				
	Siddhirganj (2x120 MW)	52.0	0.0				
	HPS (100 MW)	16.0	0.0				
	HPS(EGCB) 412 MW	68.0	65.6				
	Meghnaghat IPP 450 MW	75.0	70.0				
	Summit Meghn. 335 MW	55.0	0.0				
	RELIANCE POWER (718MW)	130.0	9.8				
	RPCL (210 MW)	40.0	4.2				
	Madhabdi (27+10 MW) REB	9.0	5.5				
	Ashulia (24+10 MW) REB	10.0	3.5				
	Doreen Tangail 22 MW SIPP	5.0	0.0				
	Doreen Narsingdi 22 MW SIPP	5.0	0.0				
	Maona 33 MW SIPP	8.0	7.5				
	Rupganj 33 MW SIPP	8.0	2.7				
EGCB Shidhirgonj 335 MW	55.0	53.5					
HPL ( 360 MW )	55.0	0.0					
Regent 108 MW	27.0	0.0					
	<b>Sub-Total</b>	<b>996.0</b>	<b>259.2</b>		<b>117.0</b>	<b>73.7</b>	<b>1142.2</b>
BGDCL	Ashuganj 500 MW*			AFCL	52.0	0.0	* United. 200 MW Modular Shutdown. * APS 450 MW CAPP S Shutdown. * Ashuganj -80 MW Rent Shutdown * Feni-22 MW SIPP Shutdown. * Mohipal-11 MW SIPP Shutdown. * Jangalia-33 MW SIPP Shutdown * AFCL Shutdown.
	Ashuganj 55 MW rental	71.0	12.9				
	Ashuganj 53 MW rental						
	Ashuganj -80 MW Rent	0.0	0.0				
	Ashuganj 225MW	40.0	38.2				
	United. 200 MW Modular	40.0	0.0				
	APS 450 MW CAPP S	65.0	0.0				
	APS 450 MW CAPP N	65.0	49.6				
	APS 450 MW CAPP E	75.0	49.9				
	Feni-22 MW SIPP	5.2	0.0				
	Mohipal-11 MW SIPP	2.7	0.0				
	Jangalia-33 MW SIPP	7.8	0.0				
Chandpur 150 MW CAPP	34.0	14.7					
Comilla REB 24 MW	6.2	3.7					
Midland Power 51 MW	12.0	8.9					
	<b>Sub-Total</b>	<b>423.9</b>	<b>178.0</b>		<b>52.0</b>	<b>0.0</b>	<b>96.2</b>
KGDCL	Raozan (2x210) MW	95.0	0.0	CUFL	52.0	44.7	* Sikalbaha 40,225 shutdown * Raozan (2x210) unit 1 MW Shutdown. * Barabkunda 22 MW SIPP Shutdown.
	Sikalbaha (40 MW)	12.0	0.0	KAFCCO	63.0	44.8	
	Sikalbaha (225+150+65) MW	73.0	37.1				
	Barabkunda 22 MW SIPP	5.0	0.0				
	<b>Sub-Total</b>	<b>185.0</b>	<b>37.1</b>		<b>115.0</b>	<b>89.5</b>	<b>160.4</b>
JGTDSL	Shahjibazar 2x30 MW	18.0	16.8	SFCL	45.0	40.3	* S.Bazar 3 yrs rental 50 MW Shutdown. * S.Bazar 330 MW Shutdown. * S.Bazar 100 MW Shutdown. * K.gaoon 3 yrs rent 50 MW Shutdown. * K.gaoon 15 yrs rent 10 MW Shutdown. * Bibiyana-S.400 MW,PDB Shutdown.
	S.Bazar 3 yrs rental 50 MW	12.0	0.0				
	S.Bazar 15 yrs rent 86 MW	20.0	19.3				
	S.Bazar 330 MW	47.0	0.0				
	S.Bazar 100 MW	18.0	0.0				
	Fenchuganj CC1 90 MW	17.0	9.1				
	Fenchuganj CC2 105 MW	18.0	9.1				
	Kumargaon 20 MW	2.0	2.8				
	K.gaoon 3 yrs rent 50 MW	12.0	0.0				
	K.gaoon 15 yrs rent 10 MW	3.0	0.0				
	K.gaoon 142 MW CAPP	36.0	36.7				
	Habiganj 11 MW SIPP	3.0	1.6				
	F.ganj 15 yrs rent 51 MW	13.0	11.4				
	F.ganj 3 yrs rent 50 MW	10.0	7.9				
	Shahjahanullah pgcl Rent	5.0	2.7				
	Bibiyana-2 341 MW	50	49.5				
	Bibiyana-3 400 MW	40	59.5				
Bibiyana-S.400 MW,PDB	43	0.0					
Khushiyara 163 MW	28	28.5					
	<b>Sub-Total</b>	<b>395.0</b>	<b>255.0</b>		<b>45.0</b>	<b>40.3</b>	<b>107.8</b>
PGCL	Baghabari (100+71 MW)	50.0	0.0				* Baghabari (100+71 MW) Shutdown. * Bogra 3 yrs rent (20 MW) Shutdown. * Bogra 15 yrs rent (20 MW) Shutdown. * NWPGL Unit -2,3 Shutdown.
	Bogra 15 yrs rent (20 MW)	5.0	0.0				
	Ullapara 11 MW SIPP	3.0	1.1				
	Bogra 3 yrs rent (20 MW)	5.0	0.0				
	NWPGL Unit -1	38.0	34.5				
	NWPGL Unit -2	38.0	0.0				
NWPGL Unit -3	38.0	0.0					
NWPGL Unit -4	70.0	58.8					
	<b>Sub-Total</b>	<b>247.0</b>	<b>94.3</b>		<b>0.0</b>	<b>29.3</b>	<b>123.6</b>
SGCL	Bhola 3 yrs rent 34.5 MW	10.0	1.8				* Aggreko 95MW Shutdown.
	Bhola 225 MW	35.0	17.3				
	Bheramara 360MW	65.0	37.5				
	Aggreko 95MW	26.0	0.0				
NBBL 220MW	38.0	36.9					
	<b>Sub-Total</b>	<b>174.0</b>	<b>93.5</b>		<b>0.0</b>	<b>4.7</b>	<b>98.2</b>
	<b>Total :</b>	<b>2420.9</b>	<b>917.1</b>		<b>329.0</b>	<b>203.5</b>	<b>1540.7</b>
(Considering diversity factor 0.85)		<b>2058</b>			<b>280</b>		

**Non-grid power**

TGTDCI	81.0					
KGDCL	12.7					
<b>Total Non-Grid Power</b>	<b>93.7</b>					<b>93.7</b>
<b>Grand Total</b>	<b>2420.9</b>	<b>1010.8</b>		<b>329.0</b>	<b>203.5</b>	<b>2755.0</b>
% of Total Distribution		37%		7%	56%	100%